



Certificate of Compliance

Certificate: 1514630 (LR 65547)

Master Contract: 158194

Project: 2136168

Date Issued: 2009/02/25

Issued to: Guardian Telecom Inc.
7552 10 St NE
Calgary, AB T2E 8W1
Canada
Attention: Mr. Kevin Sera

The products listed below are eligible to bear the CSA Mark shown



Issued by: Ron Wachowicz, C.E.T.

Authorized by: Patricia Pasemko, Operations
Manager

PRODUCTS

CLASS 4818 02 - SIGNAL APPLIANCES - Audible - For Hazardous Locations

Class I, Division 1, Groups B, C and D; Class II, Groups E, F and G:

Telephone, wall mounted Cat. No. 401 (EX-proof) Enclosure type 4 with intrinsically safe handset P/N P000416, P/N P001302, P/N P002801, P/N P005574 or P/N P005575; 48 Vdc telephone transmission circuit), 60 to 130 V 20 hz. (ringing circuit; with optional relay contacts rated 10A, 1/3 Hp, 240 Vac; 10A, 1/3 Hp – 120 Vac; or 10 A, 30 Vdc).

APPLICABLE REQUIREMENTS



Certificate: 1514630 (LR 65547)

Master Contract: 158194

Project: 2136168

Date Issued: 2009/02/25

CSA C22.2 No. 0 M1991 - General Requirements - Canadian Electrical Code, Part II

CSA C22.2 No. 0.4 M2004 - Bonding & Grounding of Electrical Equipment (Protective Grounding)

CSA C22.2 No. 0.5 M1982 - Threaded Conduit Entries

CSA C22.2 No. 25 M1996 - Enclosures for Use in Class II Groups E, F and G Hazardous Locations

CSA C22.2 No. 30 M1986 - Explosion-Proof Enclosures for Use in Class Hazardous Locations

CSA C22.2 No. 94 M1991 - Special Purpose Enclosures

CSA C22.2 No. 157 M1992 - Intrinsically Safe Equipment for use in Class I Hazardous Locations

CSA C22.2 No. 225 M90 - Telecommunications Equipment