



Certificate of Compliance

Certificate: 1778520

Master Contract: 158194 (065547_0_000)

Project: 70178571

Date Issued: 2018-08-29

Issued to: Circa Enterprises Inc.
535, 10333 Southport Road SW
Calgary, Alberta T2W 3X6
CANADA

Attention: Kevin Sera

with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Joseph Da Silva
Joseph Da Silva

PRODUCTS

CLASS - C483801 - TELECOMMUNICATION EQUIPMENT-For Hazardous Locations

Class I, Division 2, Groups A, B, C and D; Temperature Code T5. Enclosure Type 4X.

Model WTT-30-H Water Tight Telephone. Permanently mounted. Rated: 24 - 56 Vdc, 20 - 120 mA; Ringer Sensitivity: 40 - 100 Volts, 16 - 25 Hz. Temperature Code T5. Enclosure Type 4X.

Model WTT-40-H Water Tight Telephone. Permanently mounted. Rated: 24 - 56 Vdc, 20 - 120 mA; Ringer Sensitivity: 40 - 100 Volts, 16 - 25 Hz. Temperature Code T5. Enclosure Type 4X.

Model WTR-41-H Water Tight Ringdown. Permanently mounted. Rated: 24 - 56 Vdc, 20 - 120 mA. Temperature Code T5. Enclosure Type 4X.

Note: All models are constructed within a Type 4X rated enclosure. Any access holes must be appropriately sealed using rated glands or plugs.

APPLICABLE REQUIREMENTS

- | | | |
|---------------------------------|---|---|
| CSA Standard C22.2 No. 0-10 | - | General Requirements, Canadian Electrical Code, Part II. |
| CSA Standard C22.2 No. 0.4-04 | - | Bonding and Grounding of Electrical Equipment (Protective Grounding). |
| CSA Standard C22.2 No. 0.5-1982 | - | Threaded Conduit Entries. (Reaffirmed 1992) |
| CSA Standard C22.2 No. 94-M91 | - | Special Purpose Enclosures. |



Certificate: 1778520
Project: 70178571

Master Contract: 158194
Date Issued: 2018-08-29

CSA Standard C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2
Hazardous Locations (Reaffirmed 1992)
CAN/CSA-C22.2 No. 60950-1- - Information Technology Equipment – Safety – Part 1: General
07+A1:2011+A2:2014/ANSI/UL Requirements
60950-1-2014



Supplement to Certificate of Compliance

Certificate: 1778520

Master Contract: 158194 (065547_0_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70178571	2018-08-29	Update Report 1778520 to include alternative receiver, microphone and enclosure material.
2631035	2013-07-19	Update report 1778520 to include new drawings structure changes, add alternate housing, optional components and optional high volume version for the Models WTT-30H, WTT-40H & WTR-41H.
2136164	2009-02-19	Update report 1778520 to add alternate Potting compounds used for barriers & circuit encapsulation and remove specific reference to a few components; assumes suitable for application with only a paperwork review.
1778520	2006-11-02	Supersedes report 65547-28. New report number 1778520 to include an alternate keypad, receiver cartridge and potting material, model designation change, new Model WTT-30-H and new Model WTR-41-H along with the replacement of all figures.